

## C Series Resistance Repeater

### → Introductions

This resistance repeater converts the resistance signals to 1:1 resistance signals.

The input, output, and power supply are galvanically isolated from each other. It can be interfaced with all kinds of device, such as DCS, PLC and other systems.

### → Parameters

#### Power supply:

Connection type: Terminals (14+, 15-) or DIN rail connector

Rated voltage: 18 V DC ~ 60 V DC (Recommended voltage: 24 V DC)

#### Input (1, 2, 3; 4, 5, 6):

Input signal: 2/3-wire resistance signal

Signal range: 18 Ω ~ 400 Ω

Line resistance: ≤ 20 Ω per line

#### Output (7, 8, 9; 10, 11, 12):

Output signal: 1:1 input resistance signal

Output drive current: 0.1 ~ 10 mA

#### Transmission characteristics:

| Output drive current | Accuracy   |
|----------------------|--|
| 0.5 ~ 10 mA          | ± 0.1% F.S. or < 0.2 Ω<br>(Choose the maximum value) |

NOTE: The transmission accuracy of resistance decreases with the decrease of drive current.

Response time: ≤ 0.5 s

Temperature drift: 30 ppm/°C

Electromagnetic compatibility: Accordance to IEC 61326-3-1

Dielectric strength (1 mA leakage current, 1 minute test time):

≥ 1500 V AC (Input /Output/Power supply)

Insulation resistance: ≥ 100 MΩ (Input /Output/Power supply)

#### Ambient conditions:

Operation temperature: -20 °C ~ +60 °C

Relative humidity: 10% RH ~ 90% RH (40 °C)






Atmosphere pressure: 80 kPa ~ 106 kPa

Storage temperature: -40 °C ~ +80 °C

Power dissipation: 0.4 W

| Model number                |            | Output1               | Output2               | Power supply |          |
|-----------------------------|------------|-----------------------|-----------------------|--------------|----------|
|                             |            | 1:1 resistance signal | 1:1 resistance signal | Terminals    | DIN rail |
| Single input, single output | NPRR-C1D   | ■                     |                       | ■            |          |
|                             | NPRR-C1DPB | ■                     |                       | ■            | ■        |
| Single input, double output | NPRR-C2D   | ■                     | ■                     | ■            |          |
|                             | NPRR-C2DPB | ■                     | ■                     | ■            | ■        |
| Double input, double output | NPRR-C3D   | ■                     | ■                     | ■            |          |
|                             | NPRR-C3DPB | ■                     | ■                     | ■            | ■        |

Single input, single output



Nanjing New Power Electric Co., Ltd.



B. Snap metal lock onto mounting rail, then rotate the devices, as figure B, press down the devices onto mounting rail, make sure that the BUS connector pins of devices and BUS socket are in close contact.

C. Pry the metal lock off the rail with screwdriver as arrow shown, pull downward the springs, and rotate the devices.

D. Remove the devices as arrow shows.

○ As far as possible to mount it vertically, In order to dissipation the heat of the apparatus.